



WHICH ECONOMIC AND TECHNICAL VALUE DO INTEGRATED CHARGING SOLUTIONS YIELD FOR HIGH POWER CHARGING (HPC) PARKS?

Roman Scholdan

Consultant eMobility

P3 Group

3rd E-Mobility Integration Symposium


14 October 2019 | Dublin, Ireland 



MOTIVATION: EV ROADMAP


A wide variety of models is coming to the markets in the following years. Around half of the announced models have a range of 350 km maximum.

Timeline of today's and future xEVs*



* xEVs = Vehicles with electrified powertrain; No claim made for completeness of the announcements.

Challenges: Economical & Technical




▪ **Economical challenge:** Charging park operator

- High xEV charging powers lead to high grid connection capacities: High installation and operational costs

▪ **Technical challenge:** Grid operator

- High variation in load could lead to grid instability

Tomorrow's charging park?




Tomorrow's charging park!



Source: Fastned fast charging station
Uffenheim Germany (windkraft-journal.de)




Source: Kreisel Chimero (presseportal.de)




Source: Porsche Newsroom

Simulating the charging park operation and optimizing its component dimensions & use

1 xEV-Charging Park Load Simulation



2 xEV-Charging Park Optimization Model




*BSS = Battery Storage System


Many influencing cost factors vary from region to region and/or within great bandwidths

Example: Grid Connection Fees (GCF) on low voltage level

Capacity charge [€/kW]



Energy Rate [ct/kWh]




Further cost factors & assumptions made:

- Building cost subsidies (BCS) for grid connection: $\bar{\phi}$ 65 €/kW (vary with grid operator as well)
- BSS costs: $\bar{\phi}$ 470 €/kWh
- PV system costs: $\bar{\phi}$ 1170 €/kWp

USE-CASE


Small HPC charging park in catchment area of a German city



- Simulation time period: 20 years


xEV assumptions:

- Market Distribution:




- Arrival Frequency: Derived from highway vehicle counting (Source: German Federal Highway Research Institute)

Example: Day with the highest traffic



Maximum vehicles per day derived from xEVs arrival frequency & market distribution





- **Maximum vehicles per day:** Number of vehicles that can be charged without having to reject further vehicles
 - Depending on arrival frequency of xEVs
 - High Scenario = Max vehicles per day (100%); Medium Scenario = 50%; Low Scenario = 20%

Different charging park configurations (medium utilization scenario)


Capital Value
 = Discounted
 (Costs – Revenues)
 $i = 1\%$
 $T = 20a$
 Not included:
 Charging revenues
 & construct. costs

Components
 BSS = 150 kWh
 PV = 4.2 kWp




- **No economic advantage when assuming average costs** for analyzed solution with integrated 150 kWh BSS over the grid only solution
- **Grid connection capacity can be reduced by up to 65%**, but cost savings cannot compensate additional BSS costs
- **4.2 kWp PV plant too small to have a major impact** on the economic efficiency of the BSS

Varying building cost subsidies (BCS) [€/kW] for the grid connection point




- **150 kWh BSS only provides additional economic value** in scenarios **with a PV plant** and in areas in which **high BCS of about 165 €/kW** are charged for the grid connection point
- **Grid connection capacity can be steadily decreased down to 80 kW**, but limited effect on the economic value of the BSS, because **BCS is only charged once** during installation of the grid connection point

Varying capacity charges [€/kW] for the yearly peak load



- In contrast to BCS the **capacity charge is charged every year**, which explains its **high impact on the economic value of the BSS**
- With **above average capacity charges of 60 €/kW** cost reductions of **23%** (without PV) and **25%** (with PV) can be achieved
- In areas with **high capacity charges of around 110 €/kW** cost reductions could reach **72%**

Optimized BSS capacity depending on BSS costs





- Without PV: **Larger sized BSS (80 to 100 kWh) only economically profitable** if extra costs for BSS don't exceed **400 €/kWh**
 Assuming **average costs of 470 €/kWh** the **optimized BSS capacity** is considerably lower: **50 kWh**
 When extra costs reach **540 €/kWh** the **BSS contains no economic value** and is not installed
- With PV: **Increased profitability of the BSS:** Even at high costs (> 470 €/kWh) a small BSS (15 to 18 kWh) is installed

Provision of reserve power with the integrated BSS (150 kWh)

Abbreviations:


- FCR = Frequency Containment Reserve
- aFRR = Frequency Restoration Reserve



- Provision of **FCR as weekly product** yields **no economic benefit** due to inflexibility
- Provision of **FCR as 4h-products** could be **economically profitable** for the regarded scenario (**overall cost reductions of up to 8.5%**)
- **FRR even more economically beneficial (26%)**, because the **asymmetrical product allows avoiding grid connection fees (GCF)**
- **GCF especially limit the profitability of FCR provision:** Without GCF overall cost reductions of up to 17% could be achieved

Provision of reserve power with the integrated BSS (150 kWh)

- Abbreviations:**
- FCR = Frequency Containment Reserve
 - aFRR = Automatic Frequency Restoration Reserve
 - GCF = Grid Connection Fees



- Provision of **FCR as weekly product** yields **no economic benefit** due to inflexibility
- Provision of **FCR as 4h-products** could be **economically profitable** for the regarded scenario (**overall cost reductions of up to 8.5%**)
- aFRR even more economically beneficial (26%)**, because the **asymmetrical product allows avoiding grid connection fees (GCF)**
- GCF especially limit the profitability of FCR provision:** Without GCF overall cost reductions of up to 17% could be achieved

Conclusion & Outlook

Result Summary

- **Economical value of the integrated 150 kWh BSS highly depends on local cost factors & BSS costs**
 - No eco. advantage with average German costs
 - Big eco. potential in areas with above average capacity charges (>20 €/kW)
 - Smaller sized BSS of 50 kWh (average BSS costs) to 100 kWh (very low BSS costs) would increase the systems profitability
- **Provision of reserve power shows high potential**
 - FCR and aFRR as 4h-products
 - Grid connection fees limit economic potential

Outlook

- **Vehicle-to-grid (V2G)**
 - New source for network services and revenues
 - Examination of the revenue potential of V2G
- **Energy Management System**
 - Development based on the output of the optimization model
 - Use of machine learning algorithms