




# Determination of the integration and influencing potential of rapid-charging systems for electric vehicles in distribution grids


Marcel Kurth, M.Sc.

### Current development of EVs in Germany



1)

### National goal




2020: 1 Mio. EVs

### Charging infrastructure



Need for countrywide rapid charging infrastructure

### SLAM – Project goal



### SLAM



Schnellladenetz für Achsen und Metropolen

Countrywide rapid-charging station network for traffic axes and metropolitan areas in Germany

[www.slam-projekt.de/](http://www.slam-projekt.de/)

### Multi-objective site assessment and selection model

Identification of suitable and sustainable locations for rapid-charging infrastructure



Determination of suitable sites for rapid-charging stations in distribution grids of Düsseldorf and Stuttgart



Introduction


▶ Methodology


Investigation scope and assumptions

Results

Conclusion and outlook







Nodal potential



Clustered potential

### Integration potential $IntP_i^0$

**What is the individual  $IntP$  at all grid connection points?**

$IntP_i^0$ : maximum additional installable power to one node  $i$  considering

- Max. DT loading
- Max. cable loading
- Voltage constrains

MV grid investigations: installation of rapid-charging station at LV busbar; considering DTs' apparent power

### Influencing potential $InfP_i$

**Where in the grid are sites with sufficient  $IntP$  (e.g. >100 kW) and at the same time with small influence on the  $InfP$  of all other sites?**

Influencing potential of a rapid-charging station at node  $i$  ( $InfP_i$ ) equals the sum of the integration potential reductions of all other ( $n-1$ ) nodes

$$InfP_i = \sum_j IntP_j^0 - IntP_j^{new}, j \in N \setminus i, N = [1 \dots n]$$

**What is the max. installable charging power within a clustered square area?**

Clustered square area values equal the maximum  $IntP$  value of all nodes inside that area

**When searching for site with a certain  $IntP$  (e.g. > 100 kW), what is the lowest  $InfP$  within a clustered square area?**

Clustered square area values equal the minimum  $InfP$  value of all nodes inside the respective square area

Introduction

Methodology

▶ Investigation scope and assumptions

Results

Conclusion and outlook



# Investigation scope and assumptions

## MV grid of South Düsseldorf

### Grid data

- 18.8 km HV cable grid
- 2 HV/MV substations
- 234 km 10 kV and 25 kV MV cable grid
- 463 MV/LV distribution transformers (DT)

### Load


- $\sum S_{DT,i} = 114 \text{ MVA}$

### Constraints

- Max. Transformer loading: 100%
- Max. cable loading: 80%

Voltage  
constrains:

Voltage level	$U_{min}$
110 kV	1.00 p.u.
25 kV	0.96 p.u.
10 kV	0.97 p.u.







# Investigation scope and assumptions

## LV grid of Stuttgart-Hausen

### Grid data

- 3 separate LV grids
- DTs' apparent power: 2 x 800 kVA, 1 x 630 kVA
- 328 loads (mainly households)

### Load

- $P_i = p_{SLP,max,i} \left[ \frac{W}{Wh} \right] \cdot W_{annual,i} [kWh] \cdot CF$
- coincidence factor:

$$CF = \frac{\sum S_{DT,max}}{\sum p_{SLP,max,i} \cdot W_{annual,i}} \approx 74\%$$

- $P_i = 2.8 \dots 24 kW, \sum P_i = 903 kW$

### Constraints

- Max. transformer loading: 100%
- Max. cable loading: 100%
- Min. voltage limit: 0.9 p.u.



Introduction

Methodology


Investigation scope and assumptions

▶ Results


Conclusion and outlook



### Integration potential [kW]




### Influencing potential [kW]




- IntP mainly limited by DT overloading
- Large parts of the grid have suitable sites for 100 kW rapid-charging stations (high IntP, small InfP)

### Integration potential [kW]




### Influencing potential [kW]




IntP	0 kW	0 ... 100 kW	≥ 100 kW		
	7.9%	28.2%	63.9%		
InfP	0 kW		0 kW	0 ... 100 kW	≥ 100 kW
	36.1%		57.0%	2.4%	4.5%

- IntP mainly limited by DT overloading
- 59.4% of the DTs are suitable sites for 100 kW rapid-charging stations

### Integration potential [kW]



### Influencing potential [kW]



IntP	0 kW	0 ... 100 kW	≥ 100 kW		
	0%	61.0%	39.0%		
InfP	0 kW		0 kW	0 ... 100 kW	≥ 100 kW
	61.0%		0.9%	3.4%	34.8%

- IntP mainly limited by house connection cables
- 4.3% of the buildings are suitable for 100 kW rapid-charging stations

Introduction

Methodology

Investigation scope and assumptions

Results

▶ Conclusion and outlook



### Results – MV grid of Düsseldorf and Stuttgart


- Large number of suitable sites for 100 kW rapid-charging stations despite a worst-case load modelling assumption
- Main limiting factor for integration potential in case of installation at the DT's busbar: DTs' apparent power

### Results – LV grid of Stuttgart-Hausen

- Connection cables of most households and buildings not suitable for 100 kW rapid-charging stations
- Rare suitable sites for 100 kW rapid-charging stations (4.3%)

### Next steps

- Electric layer has to be added to the multi-objective assessment model
- Further investigations for the integration of home charging systems (11 kW) into LV grids





# Thank you for your attention



**Marcel Kurth, M.Sc.**

RWTH Aachen University  
Institute for High Voltage Technology  
Department Sustainable Distribution Systems

Tel. +49 (0) 241 / 80 49379  
m.kurth@ifht.rwth-aachen.de

Supported by:



Federal Ministry  
for Economic Affairs  
and Energy

on the basis of a decision  
by the German Bundestag

**Coauthors:**

Dipl.-Ing. Dipl.-Wirt.Ing. Markus Gödde,  
Univ.-Prof. Dr.-Ing. Armin Schnettler  
Institute for High Voltage Technology, RWTH Aachen University

Dr. Alexander Probst  
Netze BW GmbH

Dipl.-Ing. Dirk Pieper  
Netzgesellschaft Düsseldorf mbH